



KEYED NOTES:

- 1 2"WALL CLEAN-OUT SHALL BE INSTALLED ABOVE THE FIXTURE CONNECTION FITTING, SERVING EACH URINAL, REGARDLESS OF THE LOCATION OF THE URINAL IN THE BUILDING. CPC 2016 707.4
- $\langle 2 \rangle$ CONTRACTOR SHALL MAINTAIN V.T.R. 10'-0"MIN DISTANCE AWAY FROM ALL ROOF TOP A/C UNIT'S FRESH AIR INTAKE.
- $\langle 3 \rangle$ PROVIDE CIRCUIT SOLVER CS-3/4-120, THERMOSTATIC
- $\langle 4 \rangle$ provide point of use thermostatic mixing value,
- $\langle 5 \rangle$ COLD WATER DN IN WALL. PROVIDE SOV AT 5'-0" A.F.F. W/ ACCESS
- $\langle 6 \rangle$ water hammer arrester (wha) w/ access panel.
- $\langle \overline{7} \rangle$ TRAP PRIMER DEVICE, (<u>TP-1</u>) W/ ACCESS PANEL. EXTEND

